



RATE-OF-FLOW VALVE with SOLENOID (On-Off) FEATURE

01/06

950 Series

—Model— **950-15**
650-15

Operation

The AMES Model 950-15 / 650-15 Rate of Flow Control Valve with Solenoid (On-Off) Feature is designed to automatically limit flow rate to a constant, adjustable maximum and open allowing flow control action, or close drip-tight as commanded by the Solenoid Pilot. It is controlled by a normally open, differential control pilot designed to: 1) Open (allowing fluid out of the main valve cover chamber) when the differential pressure across the orifice plate is below its adjustable set point, and, 2) Close (allowing fluid to fill the main valve cover chamber) when the differential pressure across the orifice plate is above its adjustable set point. A decrease in differential pressure causes the valve to modulate towards an open position, increasing flow rate. An increase in differential pressure causes the valve to modulate towards a closed position, decreasing flow rate.

The Solenoid Pilot will either open to allow regulating action, or close the valve drip-tight when energized. **Specify energize to open or close the Main Valve and voltage PRIOR to ordering.**

The Orifice Plate Assembly should be installed three to five pipe diameters downstream of the Model 950-15 / 650-15, and field connected with 3/8" minimum copper tubing in accordance with factory piping schematic. Please specify desired flow rate prior to ordering.

Installation Guidelines

- Prior to installation, flush line to remove debris.
- Install valve horizontally "in line" (cover facing UP), so flow arrow matches flow through the line. Avoid installing valves 6" or large vertically. Consult factory **prior** to ordering if installation is other than described.
- Install inlet and outlet isolation valves. **NOTE:** When using butterfly valves, insure disc does not contact control valve. Damage or improper valve seating may occur.
- Provide adequate clearance for valve servicing and maintenance.
- Install pressure gauges to monitor valve inlet and outlet pressure.
- Install Orifice Plate Assembly (provided) 3 to 5 pipe diameters **downstream** of the 950 / 650 with the sensing connections offset from top of pipeline to avoid air accumulation. The Orifice Plate Assembly should not be installed next to a butterfly valve.
- Connect Orifice Plate Assembly to Rate-of-Flow Pilot using 3/8" diameter minimum copper tubing (field installed) in accordance with factory piping schematic.
- Connect Solenoid to proper electrical source in compliance with local electrical codes.

Other AMES Rate-of-Flow Control Valves

950 / 650	Rate-of-Flow Control Valve
950-01 / 650-01	Rate-of-Flow Control Valve with Hydraulic Check Feature
951 / 651	Rate-of-Flow Control Valve with Pressure Reducing Feature
952 / 652	Rate-of-Flow Control Valve with Pressure Sustaining Feature