

---

**Classic Series**

---

**F110-AS (Globe)**  
**F1110-AS (Angle)**

### Operations

The Watts ACV Modulating Float Control Valve with Solenoid (On-Off) Feature is designed to automatically maintain a constant liquid level in a tank or reservoir, and open, allowing level control action, or close drip-tight as commanded by the Solenoid Pilot. It is controlled by a remote mounted Modulating Float Pilot designed to: 1) Modulate Open (allowing fluid out of the main valve cover chamber) when reservoir level decreases, and, 2) Modulate Closed (allowing fluid to fill the main valve cover chamber) when reservoir level increases. A decrease in reservoir level causes the valve to modulate towards an open position, allowing reservoir level to increase. An increase in reservoir level causes the valve to modulate towards a closed position, allowing reservoir level to decrease.

The Solenoid Pilot will either open to allow regulating action, or close the valve drip-tight when energized. **Specify energize to open or close the Main Valve and voltage PRIOR to ordering.**

If desired, the modulating action of the valve can be “reversed” by inverting or “reversing” the action of the Modulating Float Pilot. The Modulating Float Control is remotely mounted from the valve, and field connected with 3/8” minimum copper tubing in accordance with factory piping schematic.

### Installation Guidelines

- Prior to installation, flush line to remove debris.
- Install valve horizontally “in line” (cover facing up), so flow arrow matches flow through the line. Avoid installing valves 6” and larger vertically. Consult factory **prior** to ordering if installation is other than described.
- Install inlet and outlet isolation valves. **NOTE:** When using butterfly valves, insure disc does not contact control valve. Damage or improper valve seating may occur.
- Provide adequate clearance for valve servicing and maintenance.
- Install pressure gauge to monitor valve inlet pressure.
- Connect Modulating Float Control to main valve using 3/8” diameter minimum copper tubing (field installed) in accordance with factory piping schematic.
- Modulating Float Control should be mounted in a field installed “stilling well” for protection against surface turbulence and interference.
- Connect Solenoid to proper electrical source in compliance with local electrical codes.

### Other Watts ACV Float Control Valves

|                    |   |
|--------------------|---|
| F110-10 / F1110-10 | Modulating Float Control Valve                                  |
| F110-13 / F1110-13 | Modulating Float Control Valve with Pressure Sustaining Feature |
| F110-14 / F1110-14 | On-Off Float Control Valve                                      |
| F110-18 / F1110-18 | On-Off Float Control Valve with Pressure Sustaining Feature     |