



February 12, 2010

Joseph Burke, P.E.
Watts Regulator
815 Chestnut Street
Andover, MA 01845

Dear Mr. Burke:

NSF has reviewed the submission identified below. Based on the product literature, product specifications, metal certification statements and product drawings submitted, the product(s) covered contain a weighted average lead content of less than or equal to 0.25%.

LF825Y
LF825YA

Sizes $\frac{3}{4}$ " - 2"

The weighted average lead content has been calculated using the following formula: The percentage of lead content within each component that comes in contact with water was multiplied by the percent of the total wetted surface of the entire product represented in each component containing lead. These percentages were added and the sum constitutes the weighted average lead content of the product.

These products also meet the requirements of NSF Low Lead Certification Program. For a listing of NSF Certified products, visit www.nsf.org. This letter remains active for one (1) year

Sincerely,

A handwritten signature in black ink, appearing to read "Nancy M. Cistulli".

Nancy M. Cistulli
Certification Project Manager
Plastic Piping System Components

email: ncistulli@nsf.org
Phone: 734-827-5673
Fax: 734-827-7895